




ENCLOSURE INFORMATION	
KD700-750	kg [LBS]
ALUM. SOUND L2 ENCLOSURE WEIGHT	1510 [3300]
ALUM. SOUND L1 ENCLOSURE WEIGHT	1240 [2730]

TANK INFORMATION				
LITERS [GALLONS] MIN HOURS	GENSETS	TANK WEIGHT kg [LBS] (N O F E E)	VERTICAL C.G. DIM A MM [I INCH]	HORIZONTAL C.G. DIM B M M [INCH]
4829 [1275] 24 HOURS STANDARD	KD700-750	25 20 [55]	285 [11. 2]	3045 [119.9]

NOTE:
TANK WEIGHT + ENCLOSURE WEIGHT + GENERATOR SET WEIGHT
(REFERENCE FROM GENERATOR SET ADV) = TOTAL WEIGHT

KD700-750
SL1 / SL2 ENCLOSURE
STANDARD 24 HR TANK

REV	DATE	CHANGE NUMBER	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
A	04AUG2022	CT221497	NEW DRAWING	PAR
B	28FEB2023	CT225762	SEE SHEET 9,10 & 11	APB

THIRD ANGLE PROJECTION

MAJOR ○ = ●

CRITICAL ◆ = ○

CHARACTERISTICS COMPLY WITH KPS-80022

DRAWN BY PAR

APPROVED BY AJW

DATE: 04AUG2022


DO NOT SCALE.
THIS ASSEMBLY OR PART MUST
COMPLY WITH PEP-RML-001.
REFERENCE CAD MODEL FOR
UNSPECIFIED DIMENSIONS.

KOHLER.
KOHLER, WISCONSIN 53044

SCALE: 0.025 SHEET SIZE: B SHEET 1 OF 12

TITLE:
DIMENSION PRINT KD700-750
TANK & ENCL.

DWG NO.: **ADV-9222**




ENCLOSURE INFORMATION	
KD 700-750	kg [LBS]
ALUM. SOUND L3 DISCHARGE SECTION	150 [331]
ALUM. SOUND L3 ENCLOSURE WEIGHT W/DISCHARGE SECTION	1810 [3990]
ALUM. SOUND L3 ENCLOSURE WEIGHT W/O DISCHARGE SECTION	1660 [3660]


NOTE:
TANK WEIGHT + ENCLOSURE WEIGHT + GENERATOR SET WEIGHT
(REFERENCE FROM GENERATOR SET ADV) = TOTAL WEIGHT

KD700-750
SL3 ALUMINIUM
WITH DISCHARGE SECTION

550 GALLON STATE TANK SHOWN				
REV	DATE	CHANGE NUMBER	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
A	04AUG2022	CT221497	NEW DRAWING	PAR
B	28FEB2023	CT225762	SEE SHEET 9,10 & 11	APB

DO NOT SCALE. THIS ASSEMBLY OR PART MUST COMPLY WITH PEP-RML-001. REFERENCE CAD MODEL FOR UNSPECIFIED DIMENSIONS.		
KOHLER. KOHLER, WISCONSIN 53044		
SCALE: 0.023	SHEETSIZE: B	SHEET 2 OF 12
TITLE: DIMENSION PRINT KD700-750 TANK & ENCL.		
DWG NO.: ADV-9222		





5025 GALLON 96 HR. STATE TANK SHOWN

NOTE:


TANK WEIGHT + ENCLOSURE WEIGHT + 2X ENCLOSURE I-BEAM SUPPORTS (110KG EACH, 220KG TOTAL) + GENERATOR SET WEIGHT (REFERENCE FROM GENERATOR SET ADV) = TOTAL WEIGHT


KD700-750
SL1 / SL2 ENCLOSURE
STANDARD 48 HR TANK,
STATE 48 / 72 / 96 HR TANK


TANK INFORMATION								
LITERS [GALLONS] MIN HOURS	GENSETS	DIM F MM [INCH]	DIM G MM [INCH]	DIM H MM [INCH]	DIM J MM [INCH]	TANK WEIGHT kg [LBS] (NO FUEL)	VERTICAL C.G DIM K MM [INCH]	HORIZONTAL C.G DIM L MM [INCH]
9577 [2530] 48 HOURS STATE	KD700-750	7045 [277.4]	787 [31.0]	2590 [102.0]	345 [13.6]	4800 [10582]	380 [15.0]	3400 [133.9]
9539 [2520] 48 HOURS STANDARD		6280 [247.2]	838 [33.0]	2590 [102.0]	345 [13.6]	4260 [9392]	420 [16.5]	2940 [115.7]
14327 [3785] 72 HOURS STATE		7500 [295.3]	914 [36.0]	3045 [119.9]	573 [22.5]	6050 [13338]	440 [17.3]	3600 [141.7]
19021 [5025] 96 HOURS STATE		9850 [387.8]	914 [36.0]	3045 [119.9]	573 [22.5]	7440 [16402]	420 [16.5]	4740 [186.6]

REV	DATE	CHANGE NUMBER	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
A	04AUG2022	CT221497	NEW DRAWING	PAR
B	28FEB2023	CT225762	SEE SHEET 9,10 & 11	APB

THIRD ANGLE PROJECTION 		DO NOT SCALE. THIS ASSEMBLY OR PART MUST COMPLY WITH PEP-RML-001. REFERENCE CAD MODEL FOR UNSPECIFIED DIMENSIONS.	
MAJOR ○ = CRITICAL ⊕ = CHARACTERISTICS COMPLY WITH KPS-80022		KOHLER. KOHLER, WISCONSIN 53044	
DRAWN BY PAR APPROVED AJW		DATE: 04AUG2022	
		SCALE: 0.020 SHEET SIZE: B SHEET 4 OF 12	
		TITLE: DIMENSION PRINT KD700-750 TANK & ENCL.	
		DWG NO.: ADV-9222	







KD700-750
SL1 / SL2 / SL3 CERTIFICATION
MOUNTING LOCATIONS

REV	DATE	CHANGE NUMBER	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
A	04AUG2022	CT221497	NEW DRAWING	PAR
B	28FEB2023	CT225762	SEE SHEET 9,10 & 11	APB

THIRD ANGLE PROJECTION

MAJOR =
CRITICAL =
CHARACTERISTICS COMPLY WITH KPS-80022

DRAWN BY PAR
APPROVED BY AJW

DATE: 04AUG2022


DO NOT SCALE.
THIS ASSEMBLY OR PART MUST
COMPLY WITH PEP-RML-001.
REFERENCE CAD MODEL FOR
UNSPECIFIED DIMENSIONS.

KOHLER.
KOHLER, WISCONSIN 53044

SCALE: 0.020 SHEET SIZE: B SHEET 7 OF 12

TITLE:
DIMENSION PRINT KD700-750
TANK & ENCL.


DWG NO.: **ADV-9222**





REV	DATE	CHANGE NUMBER	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
A	04AUG2022	CT221497	NEW DRAWING	PAR
B	28FEB2023	CT225762	SEE SHEET 9,10 & 11	APB

KD700-750
ELECTRICAL & ENCLOSURE
ACCESSORY OPTIONS

THIRD ANGLE PROJECTION 			DO NOT SCALE. THIS ASSEMBLY OR PART MUST COMPLY WITH PEP-RML-001. REFERENCE CAD MODEL FOR UNSPECIFIED DIMENSIONS.		
MAJOR ○ = CRITICAL ● = CHARACTERISTICS COMPLY WITH KPS-80022			KOHLER. KOHLER, WISCONSIN 53044		
DRAWN BY APB	PAR	DATE: 04AUG2022	SCALE: 0.040	SHEET SIZE: B	SHEET 8 OF 12
APPROVED AJW			TITLE: DIMENSION PRINT KD700-750 TANK & ENCL.		
BY			DWG NO.: ADV-9222		







9	GAUGE, FUEL LEVEL, DIRECT READ
8	PLUG, PIPE (2" NPT)
7	FILL CAP, 2" LOCKABLE W/PIPE RISER
6	SWITCH, FUEL IN BASIN TOP MTD, 2"
5	VENT, NORMAL
4	RETURN, FUEL (1/2" NPT)
3	SUPPLY, FUEL (1/2" NPT)
2	GAUGE, FUEL LEVEL, W/ SENDER
1	CAP, EMERGENCY VENT
ITEM	DESCRIPTION

660 GALLONS STATE TANK SHOWN

GROUND CLEARANCE I-BEAM
MOUNTING HOLE

KD700-750
NON ENCLOSED UNIT ONLY TANK
660 GALLON STATE TANK

REV	DATE	CHANGE NUMBER	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
A	04AUG2022	CT221497	NEW DRAWING	PAR
B	28FEB2023	CT225762	SEE SHEET 9,10 & 11	APB

THIRD ANGLE PROJECTION 			DO NOT SCALE. THIS ASSEMBLY OR PART MUST COMPLY WITH PEP-RML-001. REFERENCE CAD MODEL FOR UNSPECIFIED DIMENSIONS.		
			KOHLER. KOHLER, WISCONSIN 53044		
MAJOR ○ =	CRITICAL ⬢ =	CHARACTERISTICS COMPLY WITH KPS-80022	SCALE: 0.040	SHEET SIZE: B	SHEET 12 OF 12
DRAWN BY PAR	DATE:	APPROVED AJW	TITLE: DIMENSION PRINT KD700-750 TANK & ENCL.		
BY	04AUG2022	BY	DWG NO.: ADV-9222		